ANL-77-84 ANL-77-84

CHEMICAL ACTIVITIES OF ALKALI SULFATES IN HOT CORROSION

by

Chen C. Hsu, Irving Johnson, and Milton Blander



ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS

Prepared for the U. S. DEPARTMENT OF ENERGY
under Contract W-31-109-Eng-38

The facilities of Argonne National Laboratory are owned by the United States Government. Under the terms of a contract (W-31-109-Eng-38) between the U. S. Department of Energy, Argonne Universities Association and The University of Chicago, the University employs the staff and operates the Laboratory in accordance with policies and programs formulated, approved and reviewed by the Association.

MEMBERS OF ARGONNE UNIVERSITIES ASSOCIATION

The University of Arizona
Carnegie-Mellon University
Case Western Reserve University
The University of Chicago
University of Cincinnati
Illinois Institute of Technology
University of Illinois
Indiana University
Iowa State University
The University of Iowa

Kansas State University
The University of Kansas
Loyola University
Marquette University
Michigan State University
The University of Michigan
University of Minnesota
University of Missouri
Northwestern University
University of Notre Dame

The Ohio State University
Ohio University
The Pennsylvania State University
Purdue University
Saint Louis University
Southern Illinois University
The University of Texas at Austin
Washington University
Wayne State University
The University of Wisconsin

-NOTICE-

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately-owned rights. Mention of commercial products, their manufacturers, or their suppliers in this publication does not imply or connote approval or disapproval of the product by Argonne National Laboratory or the U. S. Department of Energy.

Printed in the United States of America
Available from
National Technical Information Service
U. S. Department of Commerce
5285 Port Royal Road
Springfield, Virginia 22161
Price: Printed Copy \$4.00; Microfiche \$3.00

Distribution Categories: Chemistry (UC-4) Coal Conversion and Utilization--MHD (UC-90g) Energy Conversion (UC-93)

ANL-77-84

ARGONNE NATIONAL LABORATORY 9700 South Cass Avenue Argonne, Illinois 60439

CHEMICAL ACTIVITIES OF ALKALI SULFATES IN HOT CORROSION

bу

Chen C. Hsu, Irving Johnson, and Milton Blander

Chemical Engineering Division

June 1978

TABLE OF CONTENTS

																													Page
ABSTR/	ACT .																•	•	•				•	•	•		•		1
I.	INTRO	ODUC	CTION				•		•			•	•	•			•		•		•	•	-	•					1
II.	CALC	ULAT	TIONS							•						•							•	•		•	•		2
III.	THER	MODY	NAMIC	EQU	ILI	BR]	LUM	ĺ								•		•	•			•		•	•				3
	Α.	The	Effec	t of	Na	C1		•	•	•		•		•	•		•	•	•		•				•	•	•	•	3
	В.	The	Effec	t of	so	2		•					•	•		•		•	•				•	•	•	•	•		5
	C.	The	Effec	t of	НС	1				•				•		•		•	•		•		•	•	•				5
	D.	The	Effec	t of	02	•						•			•	•	•	•			•				•		•		9
	Ε.	The	Effec	t of	th	e A	Add	lit	ic	on	οí	= 1	ra	ace	e K	20	203	}		•	•	•	•			•	•		9
IV.	DISC	USSI	ION .								•	•	•		•	•	•			•		•	•			•	•	•	11
v.	CONC	LUS	ION .									•	•		•		•	•				•			•	•	•		13
ACKNO	WLEDG	MENT	rs .						•			•	•		•		•			•	•	•	•	•	•	•	•	•	13
REFER	ENCES											_	_																13

LIST OF FIGURES

No.	<u>Title</u>		Page
1.	Gas Phase Equilibrium of Combustion Gas	•	4
2.	Gas Phase Equilibrium of Combustion Gas Doped with 100 ppm $\mathrm{K}_2\mathrm{CO}_3$		4
3.	Condensation Temperature of Na_2SO_4 as a Function of Pressure and NaCl Concentration	•	6
4.	Condensation Temperature of Na_2SO_4 as a Function of Pressure and Concentration of HCl and NaCl		6
5.	Condensation Temperature of K_2SO_4 as a Function of Pressure and NaCl Concentration	•	7
6.	Condensation Temperature of Na_2SO_4 as a Function of Pressure and Concentrations of SO_2 and $NaC1$		7
7.	Condensation Temperature of K_2SO_4 as a Function of Pressure and NaCl Concentration	•	8
8.	Condensation Temperature of K_2SO_4 as a Function of Pressure and Concentrations of HCl and NaCl	•	8
9.	Condensation Temperature of Na_2SO_4 as a Function of NaCl in the Absence of O_2	•	10
10.	Condensation Temperatures of K_2SO_4 and Na_2SO_4 as Functions of Pressure and K_2CO_3 Concentration	•	10
11.	Equilibrium Ratio of SO_2/SO_3	•	12
	LIST OF TABLES		
1.	Typical Composition of a Fuel-Oil Combustion Gas		2
2.	Percent Conversion of NaCl to Na $_2$ SO $_4$ and of KCl to K $_2$ SO $_4$ in a Typical Combustion Gas at 1 atm		12
3.	Percent Conversion of NaCl to Na $_2$ SO $_4$ and of K $_2$ CO $_3$ and KCl to K $_2$ SO $_4$ in a Typical Combustion Gas Doped with 100 ppm K $_2$ CO $_3$ at 1 atm		13

CHEMICAL ACTIVITIES OF ALKALI SULFATES IN HOT CORROSION

bу

Chen C. Hsu, Irving Johnson, and Milton Blander

ABSTRACT

The condensation temperatures of sodium and potassium sulfates from typical fuel-oil combustion gases were calculated as functions of the concentrations of SO_2 , HCl, NaCl and O_2 , and total combustion pressures ranging from 1 to 10 atm. Of these components, oxygen had the greatest effect on the condensation temperature of sodium sulfate, producing an increase of as much as 280 K at 10 atm. Alkali sulfate activities were least affected by sulfur dioxide, tested in the range from 93 to 270 ppm. The order of the effect on the alkali sulfates was as follows: $O_2 > HCl > NaCl > SO_2$. With the addition of K_2CO_3 , such as would occur in the magnetohydrodynamic (MHD) environment, the activity of potassium sulfate overshadowed that of sodium sulfate. The control of the activities of alkali sulfates is discussed in terms of the concentrations of the above-mentioned species and of the system pressure.

I. INTRODUCTION

One of the means of increasing the overall efficiency of the operation of a gas turbine is to increase the turbine inlet temperature. However, the increase of the turbine temperature is limited by the high-temperature strength of the superalloys which are used as turbine construction materials. With the reduction of chromium content from 20 to 10% in superalloys, the gas turbine suffers serious corrosion problems. Hot corrosion, that is accelerated oxidation, is most often attributed to the presence of trace impurities of sodium chloride and sulfur in the fuels. In the case of marine gas turbines, sodium chloride comes mainly from an aerosol of seawater. For other turbine uses, the result of corrosion analysis reveals that liquid Na_2SO_4 is the species responsible for hot corrosion.¹⁻² Experiments³⁻¹⁰ have been carried out in various laboratories to elucidate the mechanism of hot corrosion of superalloys. As a result of these investigations, Goebel and Pettit¹⁰ proposed three possible mechanisms as being involved in hot corrosion, namely, basic and acidic fluxing reactions, and sulfidation. The destruction of the protective oxide layer on the metal surface followed by depletion of the newly exposed metal by reaction with oxide ions in a Na₂SO₄ melt is called the basic fluxing reaction, while a similar reaction is called an acidic fluxing reaction if the oxide ion is donated by the oxide barrier. The formation of sulfides by reaction of the metal oxides with Na₂SO₄ gives rise to an accelerated oxidation called sulfidation. Regardless of the mechanism involved, a sufficient condition leading to catastrophic oxidation is the presence of liquid alkali sulfates in the oxidizing environment in the high-temperature combustion system. An understanding of the conditions that result in the

formation of alkali sulfates in the combustion systems becomes important to the control of hot corrosion. This is even more important in the magnetohydrodynamic (MHD) environment where a potassium salt is artifically injected as seed into the generator channel. In this report, the condensation temperatures of potassium and sodium sulfates and a thermodynamic analysis of the important species in the combustion systems are presented. In addition, optimum operational conditions for gas turbines are suggested.

II. CALCULATIONS

The stable species present in a system at equilibrium were determined by means of the NASA code^{11} for calculation of equilibrium compositions (CEC) and an ANL modification of the CEC code , 12 both of which utilize the technique of minimization of the free energy of the system. The typical composition of a fuel-oil combustion gas used for these calculations is given in Table 1.

Table 1.	Typical	Composition	οf	а
	Fuel-0il	Combustion	Gas	š .

Constituent	Concentrationa
02	9.59 mol %
N_2	76.21 mol %
CO ₂	8.57 mol %
H ₂ O	5.63 mo1 %
S0 ₂	185 ppm
HC1	40 ppm
NaC1	10 ppm
KC1	7 ppm
$a_{1 ppm} = 10^{-4} mol \%$,

The formation of the alkali sulfates as condensed phases can occur according to the reaction:

$$H_2O(g) + 2MCl(g) + SO_2(g) + 1/2 O_2(g) \neq M_2SO_4(s,l) + 2HCl(g)$$
 (1)

where M is either potassium or sodium. (Other equilibria involved in the combustion will not be discussed here.) The activities of the alkali sulfates were calculated as functions of the concentrations of NaCl, SO_2 , HCl, O_2 ; the temperature; and the system pressure. The pressure ranged from 1 to 10 atm and the temperature from 900 to 1500 K. The effect on the equilibrium of adding small amount of K_2CO_3 was also studied. Unless otherwise noted, the

criterion for determining whether a species was present at a significant level in the equilibrium mixture was set at 5 x 10^{-6} mol % (50 ppb). The composition of the combustion gas given in Table 1, which served as the baseline case, was varied in separate calculations as follows:

- (1) NaCl: 10 ppm, 1 ppm, 100 ppb, and 10 ppb
- (2) SO₂: 92.5, 185, and 270 ppm; NaCl: 10 and 1 ppm
- (3) HC1: 4, 40, and 400 ppm; NaC1: 10 and 1 ppm
- (4) O_2 : 10, 1, and 0 ppm
- (5) O_2 : 0; CO: 42.9 ppm
- (6) K_2CO_3 : 1, 10, 100, and 1000 ppm


The computer output comprised a listing of stable species and their corresponding mole fractions at equilibrium under the specified values of the temperature and pressure. The partial pressure of each species was obtained simply by multiplying the mole fraction by the system pressure.

III. THERMODYNAMIC EQUILIBRIUM


The equilibrium compositions and the condensation temperatures of the alkali sulfates are affected by the concentration of NaCl, SO2, O2, and K2CO3, in the input as well as by the system pressure. Figure 1 shows the gas phase equilibrium for a system at equilibrium with the initial gas having the typical composition listed above. At the higher temperature end, the equilibrium composition consists of NaCl, HCl and $\rm SO_2$. Notice the sharp increase of Na $_2$ SO $_4$ as the temperature is lowered. At 1192 K, Na $_2$ SO $_4$ starts to condense and a drastic decrease in the concentrations of NaCl and Na₂SO₄ occurs in the gas The concentration of HC1 increases, as expected from Eq. 1, as more of the Na₂SO₄ condenses. At the lower temperature, the equilibrium gas contains only SO2 and HCl. With the addition of 100 ppm of K2CO3 to the initial gas, the amount that would be expected in a MHD system, the equilibrium composition on the high-temperature side is gaseous K2SO4, NaCl, and HCl; and on the lowtemperature side, it is SO2 and HCl, as shown in Fig. 2. The sharp decrease in the partial pressure of gaseous K_2SO_4 and Na_2SO_4 begins at 1310 K, the temperature at which K_2SO_4 starts condensing. The decrease of NaCl concentration takes place at 1215 K when $\rm Na_2SO_4$ begins to condense. The condensation temperature of $\rm Na_2SO_4$ increases about 20 K with the addition of 100 ppm $\rm K_2CO_3$ to the input gas. Comparison of Figs. 1 and 2 shows that the HCl partial pressure is lowered from 4 x 10^{-5} atm at 1100 K to 10^{-6} atm at 1500 K by the addition of the K2CO3. A sharp increase in HCl partial pressure takes place after K2SO4 condensation begins. The effects of each gas constituent on the formation of alkali sulfates are discussed individually below.


A. The Effect of NaCl

In general, lowering the concentration of NaCl decreases the condensation temperature of Na_2SO_4 . The condensation temperature of Na_2SO_4 is decreased by 88 and 108 K at 1 and 10 atm, respectively, when the NaCl is lowered from 10 to 1 ppm. The calculations also were carried out for 100 and 10 ppb of NaCl. Although the NaCl level is again decreased by a factor of ten, the effect on the Na_2SO_4 condensation temperature is less at the lower NaCl levels. Lowering the NaCl level from 100 to 10 ppb results in a decrease of about 60 K



 $\label{eq:Fig. 1.} \textbf{Gas Phase Equilibrium of Combustion}$ Gas.





at 1 atm and 78 K at 10 atm. The results are shown in Fig. 3. Changing the system pressure from 1 to 10 atm increases the Na_2SO_4 condensation temperature by about 20 K for all four NaCl concentrations. These results are consistent with those of Westinghouse.¹³ In the presence of a higher HCl concentration (400 ppm as compared with 40 ppm), the condensation temperature of Na_2SO_4 decreases from 1192 to 1106 K at 1 atm and from 1321 to 1213 K at 10 atm with 10 ppm NaCl present; and from 1115 to 1025 K at 1 atm and from 1211 to 1115 K at 10 atm with 1 ppm NaCl present, as shown in Fig. 4.

The concentration of NaCl has little effect on the condensation temperature of K_2SO_4 . When the NaCl level is lowered from 10 ppm to 1 ppm, the condensation temperature of K_2SO_4 increases only 10 K at both 1 and 10 atm, as shown in Fig. 5. With further decreases in NaCl concentration levels to 100 ppb and 10 ppb, the K_2SO_4 condensation temperature is not different from the value observed at 1 ppm NaCl. Because the melting point of K_2SO_4 is higher than that of Na_2SO_4 (1342 vs. 1157 K), it is less important as a corrodant in combustion systems unless it condenses with Na_2SO_4 .

B. The Effect of SO₂

The change in the condensation temperature of Na₂SO₄ due to the variation of the SO₂ concentration is shown in Fig. 6. The increase in the condensation temperature of Na₂SO₄ owing to a doubling of the concentration of SO₂ (185 ppm as base concentration) with 1 ppm NaCl present is only 5 K at 1 atm and 15 K at 10 atm. With half of the base SO2 concentration, the condensation temperature decreases 15 K at 1 atm and 20 K at 10 atm. With 10 ppm of NaCl present, the temperature changes are almost identical to those with 1 ppm NaCl except that the Na2SO4 condensation temperature undergoes a shift to higher temperatures; this shift is 75 K at 1 atm and 110 K at 10 atm. In the case of K_2SO_4 , the condensation temperature is fairly insensitive to the increase and decrease in concentrations of SO₂ and NaCl (see Fig. 7). This is to be expected because the activity of SO2 remains very high at equilibrium in the temperature range of interest, Fig. 1. The former case has been verified experimentally by Hanby, 14 who found that there is no significant effect on the sulfation rate of NaCl when the sulfur content of the fuel is reduced from 1 to 0.1 wt % (thus reducing the SO_2 content of the combustion gas also).

C. The Effect of HCl

An increase in HCl concentration causes the condensation temperature of Na_2SO_4 to decrease considerably. Figure 4 shows the results of three different HCl concentrations, 4, 40, 400 ppm with two NaCl concentrations, 10, and 1 ppm. The decrease in the Na_2SO_4 condensation temperature with 1 ppm NaCl present is about 90 K at both 1 and 10 atm when the HCl concentration is increased from 40 to 400 ppm. It is about the same for the increase from 4 to 40 ppm HCl, except at lower pressures, where the decrease is 75 K. These results apply to the case with 10 ppm NaCl present, except that the condensation temperature of the Na_2SO_4 is systematically shifted 80 K higher for all concentrations of HCl. This trend is expected since an increase in NaCl concentration gives rise to an increase in sodium ion concentration and this in turn leads to an increase in the concentration of Na_2SO_4 . In the case of K_2SO_4 , the increase in HCl concentration from 40 to 400 ppm with 10 ppm NaCl present causes a decrease in the condensation temperature of K_2SO_4 (see Fig. 8). It should be noted that at






Fig. 3. $\label{eq:condensation} \text{Condensation Temperature of Na}_2SO_4 \text{ as a}$ Function of Pressure and NaCl Concentration.









Fig. 5.

Condensation Temperature of $\rm K_2\,SO_4$ as a Function of Pressure and NaCl Concentration.

Fig. 6.

Condensation Temperature of Na_2SO_4 as a Function of Pressure and Concentrations of SO_2 and NaCl.







Fig. 7.

Condensation Temperature of $\rm K_2SO_4$ as a Function of Pressure and NaCl Concentration.

Fig. 8.

Condensation Temperature of $K_2\,\mathrm{SO}_4$ as a Function of Pressure and Concentrations of HCl and NaCl.



400 ppm HCl, the condensation temperature of K_2SO_4 is almost identical for both 1 ppm and 10 ppm NaCl, thereby indicating that, at this level of HCl concentration, the K_2SO_4 condensation temperature is independent of NaCl concentration.

D. The Effect of O_2

In order to understand the effect of oxygen on the formation of Na2SO4, the calculation was first carried out without free oxygen in the input combustion gas. The results are shown in Fig. 9. With 10 ppm NaCl present, the decrease in the Na_2SO_4 condensation temperature is 125 K at 1 atm and 148 K at 10 atm, whereas with 1 ppm NaCl, the decrease is 220 K at 1 atm and 235 K at 10 atm. This clearly suggests that the formation of condensed Na_2SO_4 depends very strongly on oxygen activity. The calculation was carried out further by replacing the free oxygen in the input gas with 42.9 ppm of CO in the presence of 10 ppm NaCl. The condensation temperature of Na₂SO₄ decreased by 250 K at 1 atm and by 280 K at 10 atm. These results imply that under certain reducing conditions in the turbine, condensation of Na₂SO₄ can be avoided. K2SO4, the effect of no free oxygen is not as great as it was for Na2SO4, as can be shown from the results of condensation temperature calculations with the typical composition of a combustion gas, except that the NaCl was 1 ppm (see Fig. 9). With 1 ppm NaCl, the reduction in the K₂SO₄ condensation temperature is 134 K at 1 atm and 160 K at 10 atm. If the operational temperature remains higher than 930 K, the condensation of K_2SO_4 would not take place. is in consonance with the consideration of operating an MHD combustor under slightly reducing conditions to prevent the condensation of alkali sulfates, especially K2SO4.

E. The Effect of the Addition of Trace K₂CO₃

In the MHD environment, the potassium concentration is much higher than that of sodium since potassium salts are injected into the MHD generator as seed to create a high plasma density with high velocity. The equilibrium compositions of the combustion gas were altered drastically as a result of doping with a trace amount of K_2CO_3 , as may be seen by comparing Figs. 1 and 2. Consequently, the condensation temperature of Na₂SO₄, as well as that of K_2SO_4 , is affected to a great extent. For Na_2SO_4 , the condensation temperature is decreased from 1192 to 936 K with 1000 ppm of K_2CO_3 , (Fig. 10). reversal of the trend of increasing condensation temperature for concentrations of K2CO3 that are less than 100 ppm, although the increase is not significant (about 15 K). No change in the condensation temperature of Na₂SO₄ occurred with the addition of 1 ppm K_2CO_3 . In the case of K_2SO_4 , the increase in the condensation temperature is considerable: 35, 125, 275, and 320 K with additions of 1, 10, 100, and 1000 ppm K_2CO_3 , respectively, at 1 atm; and 45, 135, and 315 K with additions of 1, 10, and 100 ppm K_2CO_3 , respectively, at 10 atm. To prevent the hot corrosion problems due to liquid K_2SO_4 in the temperature range from 1500 to 900 K, the amount of K_2CO_3 must be kept below 100 ppm, a concentration below which K₂SO₄ condenses as a solid without going through the liquid-to-solid transformation.





Fig. 9. $\label{eq:condensation} \text{Condensation Temperature of Na}_2SO_4 \text{ as a Function of NaC1 in the Absence of } O_2\,.$

Fig. 10.

Condensation Temperatures of K_2SO_4 and Na_2SO_4 as a Function of Pressure and K_2CO_3 Concentration.



IV. DISCUSSION

The results obtained above are based on a thermodynamic equilibrium model. Although the residence time in the combustion chamber might be too short to allow equilibrium to be achieved, the instantaneous concentration of alkali sulfates can greatly exceed the equilibrium concentration due to nonuniformity of the gas concentration. In the MHD environment, to decompose NO_{X} to an environmentally acceptable level, a 2-s residence time has been suggested, a time that would allow sufficient time for the combustion gas equilibrium to occur. Despite some expected departures from equilibrium, the equilibrium model retains its value as a method for the prediction of the optimum conditions of operation.

Two methods may be considered for avoiding hot corrosion: (1) avoid the initial reaction between the liquid alkali sulfates and the protective metal oxide and (2) prevent the corrosive alkali sulfates from condensing in combustion systems. With respect to the first method, refractory oxides coatings have been considered and used; this subject has been reviewed in detail by Chatterji, Devries and Romeo. 15 With respect to the second method, the most powerful operational parameter is the control of the free oxygen concentration so that the combustion system is operated under slightly reducing conditions (see e.g., Fig. 9). The condensation of Na₂SO₄ as a liquid can be prevented by control of (a) the concentration of NaCl below 1 ppm (see, e.g., Fig. 3) and/or (b) the concentration of HCl to 40 ppm or higher (see Fig. 4). Another parameter is the control of pressure. According to the results presented (Figs. 3-10) the higher the system pressure, the higher will be the Na₂SO₄ condensation temperature. For optimum operation, a median system pressure such as 5 atm is suggested. Chemical additives can also be used. Harada 16 reported the effectiveness of injecting magnesium hydroxide into the fuel to prevent hot corrosion problems in heavy-oil-fired boilers. In the MHD environment, the K2CO3 level should not exceed 100 ppm at temperatures below 1500 K to avoid the condensation of liquid K2SO4 on the walls.

In principle, there is enough sulfur present in the combustion gas to convert all the alkalis into sulfates, or complex sulfates such as K3Fe(SO4)3 and $K_3Al(SO_4)_3$. However, in practice, this is not the case since sulfur maintains an equilibrium between SO_2 and SO_3 according to the reaction $SO_3 \neq SO_2 + 1/2 O_2$. The concentration ratios of SO_2 and SO_3 at various temperatures and pressures are shown in Fig. 11. At higher temperatures and lower pressures, the equilibrium is in favor of SO2, whereas, at lower temperatures and higher pressures, SO3 is dominant. Figure 11 also shows that at the pressure close to that of conventional boilers, only a small amount of SO_3 exists in the combustion gas, as has been observed. Although SO_3 was reported to be the species responsible for the formation of alkali complex sulfates and pyrosulfates, no such indication of the formation of SO3 was seen in this calculation. The percentages of sulfate conversion from NaCl, K_2CO_3 and KCl are shown in Tables 2 and 3. With the addition of 100 ppm K_2CO_3 to the combustion gas, 99% or more conversion to K_2SO_4 took place at about 1005 K, which is 55 K higher than when no K2CO3 was present. According to Table 3 at 1110 K, Na₂SO₄ and K₂SO₄ are condensed largely as solid. The ideal binary solution model of the ANL-modified NASA CEC code was used to examine the possibility of solutions between Na2SO4 and K2SO4. The result of the calculation indicates that the solid solution of both salts starts forming at temperatures of about 1174 K.




Fig. 11. Equilibrium Ratio of SO_2/SO_3

Table 2. Percent Conversion of NaCl to Na₂SO₄ and of KCl to K_2 SO₄ in a Typical Combustion Gas at 1 atm.

Conversion	Temperature, K								
Product	1500	1400	1300	1175	1050	950			
Na ₂ SO ₄ (g)	0.003	0.02	0.13	0.97	0.03	0			
Na ₂ SO ₄ (l)	0	0	0	30.08	0	0			
Na ₂ SO ₄ (s)	0	0	0	0	97.78	99.22			
K ₂ SO ₄ (s)	0	0	0	0	8.38	97.11			

Table 3. Percent Conversion of NaCl to Na₂SO₄, and of K_2CO_3 and KCl to K_2SO_4 in a Typical Combustion Gas Doped with 100 ppm K_2CO_3 at 1 atm.

Conversion			Temper	ature, K		
Product	1500	1410	1305	1200	1110	1005
K ₂ SO ₄ (g)	34.76	63.22	51.99	4.47	0.21	0.02
K ₂ SO ₄ (s)	0	0	26.41	83.85	97.23	99.85
Na ₂ SO ₄ (g)	0.46	2.82	7.10	1.72	0.16	0
Na ₂ SO ₄ (1)	0	0	0	18.28	0	0
Na ₂ SO ₄ (s)	0	0	0	0	82.18	99.25

V. CONCLUSION

The equilibrium composition of the combustion gas and the condensation temperatures of sodium and potassium sulfates have been calculated as a function of the concentrations of NaCl, HCl, SO₂ and O₂, and the system pressure. It was found that the order of the effectiveness of controlling the chemical activities of alkali sulfates is O₂ > HCl > NaCl > SO₂. A system pressure of about 5 atm, concentrations of NaCl of less than 10 ppm, and concentrations of HCl of 40 ppm or higher are suggested as optimum operational conditions in the oxidizing environment. However, the use of a reducing environment is most effective. In the open-cycle MHD system, the level of K_2CO_3 of 100 ppm or lower is considered to be the optimum concentration in the temperature range from 1500 to 900 K.

ACKNOWLEDGMENTS

This work was sponsored by the U. S. Department of Energy, Power Systems Division, and the Environmental Protection Agency. The authors appreciate the use of the NASA computer program for this calculation. The encouragement from C. E. Johnson to one of the authors (CCH) is gratefully acknowledged.

REFERENCES

- 1. H. T. Shirley, J. Iron Steel Inst. 182, 144 (1956).
- 2. S. A. Goldberg, J. J. Gallagher and A. A. Orning, J. Eng. Power 90, 193 (1968).
- 3. J. A. Goebel and F. S. Pettit, Met. Trans. 1, 1943 (1970).
- 4. A. U. Seybolt, Trans. TMS-AIME 242, 1955 (1968).
- 5. P. A. Bergman, Corrosion 23, 72-81 (1967).

- 6. N. S. Bornstein and M. A. DeCrescente, Met. Trans. 2, 2875 (1971).
- 7. A. U. Seybolt, General Electric Research and Development Center, Report No. 70-C-189 (June 1970).
- 8. J. A. Goebel, F. S. Pettit, and G. W. Goward, Met. Trans. 4, 261 (1973).
- 9. N. S. Bornstein, M. A. DeCrescente, and H. A. Roth, MCIC-73-19 (1973).
- 10. J. A. Goebel and F. S. Pettit, *Metal-Slag-Gas Reaction and Processes*, Z. A. Foroulis and W. W. Smeltzer, Eds., Electrochem. Soc., Princeton, New Jersey, pp. 693-710 (1975).
- 11. S. Gordon and B. McBride, Computer Program for Calculation of Complex Chemical Compositions, Rocket Performance, Incident and Reflected Shocks, and Champan-Jouquet Detonations, NASA sp-273 (1971).
- 12. C. C. Hsu, R. Land, and M. Blander, Binary Solution Model for Computation of Equilibrium Compositions, Argonne National Laboratory Report ANL-77-83 (1978).
- 13. K. L. Keairns et al., Fluidized Bed Combustion Process Evaluation, EPA-650/2-75-027-C (September 1975).
- 14. V. I. Hanby, Sodium Sulphate Formation and Deposition in Marine Gas Turbines, J. Eng. Power 96, 129 (April 1974).
- 15. D. Chatterji, R. C. Devries, and G. Romeo, *Protection of Superalloys* for Turbine Applications, Advances in Corrosion Science and Technology 6, M. G. Fontana and R. W. Stachle, Eds., p. 10, Plenum Press, New York (1976).
- 16. Yohio Harada, High Temperature Corrosion in Heavy Oil Firing Boilers, Proc. 5th Int. Congr. Met. Corros. (1974).
- 17. Corrosion and Deposits in Coal- and Oil-Fired Boilers and Gas Turbines, Battelle Memorial Institute, ASME Research Publication (1959).

Distribution for ANL-77-84

Internal:

P. E. Blackburn M. Blander

D. Bomkamp L. Burris

F. A. Cafasso

L. Carlson

L. Chow E. Doss

J. Hafstrom

C. C. Hsu (15)

H. Huang

K. Im

C. E. Johnson (3)

I. Johnson

T. R. Johnson G. M. Kesser

D. Killpatrick

A. B. Krisciunas

R. Kumar

R. H. Land

R. Loutfy

J. Patten

C. V. Pearson

M. Petrick E. G. Pewitt R. B. Poeppel W. C. Redman

A. Sheth R. Singh

K. Tempelmeyer

R. W. Weeks

G. Whittington

ANL Contract File ANL Libraries (5)

TIS Files (6)

External:

DOE-TIC, for distribution per UC-4, -90g, and -93 (391)

Manager, Chicago Operations Office

Chief, Office of Patent Counsel, CH

President, Argonne Universities Association

Chemical Engineering Division Review Committee:

C. B. Alcock, U. Toronto

R. C. Axtmann, Princeton U.

R. E. Balzhiser, Electric Power Research Inst.

J. T. Banchero, U. Notre Dame

T. Cole, Ford Motor Co.

P. W. Gilles, U. Kansas

R. I. Newman, Allied Chemical Corp.

G. M. Rosenblatt, Pennsylvania State U.

Aerodyne Research, Inc., Bedford, Mass.:

C. E. Kolb

J. Wormhoudt

V. Yousefian

B. Owens, Gilbert and Associates, Washington, D.C.

NASA Lewis Research Center:

B. E. Philips

G. Seikel

J. Smith

Pittsburgh Energy Technology Center:

P. D. Bergman

D. Bienstock

F. E. Spencer

USDOE Div. of Magnetohydrodynamics:

J. Hopenfeld

A. Licardi

R. Lightner

J. Lynch

M. Sluyter

A. Postlethwaite

